



# TOWN OF AHOSKIE

201 West Main Street  
Post Office Box 767  
Ahoskie, North Carolina 27910  
252-332-5146  
[www.ahoskie-nc.org](http://www.ahoskie-nc.org)

February 1, 2013

## 2012 Annual Collections Report

System Name: Town of Ahoskie Collections System  
Responsible Entity: Town of Ahoskie  
Responsible Person: Mayor Brien Lassiter  
P.O. Box 767  
Ahoskie, NC 27910  
252-332-5146  
Permit No.: WQCS00274

### About our Collection System:

The sewer collection system is owned, operated, and maintained by the Town. It consists of over thirty five miles of gravity and force mains, and 32 pump stations. Each day we transport an average of 650,000 gallons of wastewater to the Ahoskie Wastewater Treatment Plant for final treatment.

### System Performance:


The Town works hard to ensure the collection system is operated and maintained at a high level. One SSO(Sanitary Sewer Overflow) incident occurred on Oct. 8, 2012 at manhole B3 on S. Rhue St. This incident was reported as required by NCDENR. Public notice of the incident is attached.

### Notification:

This report is being provided to all water/sewer customers via the internet at [www.ahoskie.org](http://www.ahoskie.org) and posted at the US Post Office in Ahoskie.

### Certification:

I certify under penalty of law that this report is accurate and complete to the best of my knowledge. I further certify that this report has been made available to the users of the collection system.



Brien Lassiter, Mayor